



### ***Addendum #2 – 2016 Main Street Alley Pavement Project***

1. How is the project funded?

The project is funded through City Capital Improvement funds with no grants

2. Application of High Early concrete additive will be included as a Bid Alternate in the updated Secondary Bid.
3. Updated Primary Bid quantities reflecting 2 ft center gutter pan
4. Utility adjustments will occur as work commences to prevent the chance of covering any valves boxes, manholes etc.
5. Concrete pavement bid option questions:

- i. Is there a specific reason the City is requesting Class P?

The City used the CDOT specification for concrete pavement.

- ii. Can the concrete utilized in the concrete pavement be changed to Class D?

Class D is an acceptable alternative as long as the water cement ratio is 0.444 to offset the freeze thaw action in the concrete

- iii. Concrete Joint Specifications

The City will reference the City of Grand Junctions “Standard Concrete Detail” for joint details for concrete pavement.

6. Where is the Contractor List for those that attended the pre-meeting posted?

The Contractor List is posted on the City of Deltas RFP webpage under the news tab <<http://cityofdelta.net/rfp.html>> the list is located under the 2016 Main Street Pavement Project.

